

# AMULYAS

## FIRE & SAFETY SERVICE

Mo. 8141701212  
Email : [dharmagna2@gmail.com](mailto:dharmagna2@gmail.com)  
Nagar Palika Shopping Center  
Near City Survey Office,  
Santrampur, Pin-389260  
Dist. Mahisagar (Gujarat)

### CERTIFICATE

Cer.No. \_\_\_\_\_

To,

M/s, ... EMRS KADANA .....

#### TO WHOM SO EVER IT MAY CONCERN

Dear Sir,

This to certify that the extinguishers mentioned below is /are tested and refilled as per IS : 2190 On the relevant is standard. This / these extinguisher is/ are refilled on 20/2/2024... and guarance will stand valid up to 20/2/2025..... if self provided the seal has been broken and in satisfactory condition.

Type of Extinguisher	Capacity	Quantity
Water Co2	<u>2.5 kg</u>	<u>2</u>
D.C.P.		
Carbon Dioxide		
ABC Dry Powder		
Halon		
Modular ABC ✓	<u>6kg</u>	<u>20</u>
Foam (C)		

Please Find our Maintenance sticker

On each Fire Extinguisher for Authentication.

  
For, Amulyas Fire Service